

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance

0432-CPR-00099-09

Version 03

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

ECO TS-31, ECO TS-33, ECO TS-41

Door Closer with a controlled closing-sequence for single- and double leaf doors in accordance with the combination and classification in Annex 1

placed on the market under the name or trade mark of

ECO SCHULTE GmbH & Co. KG

Iserlohner Landstraße 89
58706 Menden, Germany

and produced in the manufacturing plant(s)

DO 2.32

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 27.10.2017 and will remain valid until 26.10.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 15th May 2024



By order

RBA Th. Meinks
Deputy Head of Certification Body Department
2230

This Certificate consists of 1 page and 1 annex(es). This certificate replaces certificate no. 0432-CPR-00099-09 dated 27.10.2022, version 02.

The original of this document was issued in German language.

In case of doubt only the German version is valid.

Materialprüfungsamt Nordrhein-Westfalen • Marsbruchstraße 186 • 44287 Dortmund • Telefon +49 (0)231 4502-0 • Telefax +49 (0)231 458549 •

MPA NRW Brandprüfzentrum Erwitte • Auf den Thränen 2 • 59597 Erwitte • Telefon +49 (0)2943 897-0 • Telefax +49 (0)2943 897-89 •

• E-Mail: info@mpanrw.de • www.mpanrw.de •

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

List of Products

Type:	„ECO TS-31“
Description:	Hydraulic door closer with controlled closing sequence with or without back check
Arm system:	slide channel arm assembly (shot and long)
Installation:	Door-leaf fixing, pull side in accordance with manufacturer specification (standard installation) Door-leaf fixing, push side in accordance with manufacturer specification Frame fixing, pull side in accordance with manufacturer specification Frame fixing, push side in accordance with manufacturer specification
Size:	1-3
Classification:	Door-leaf fixing, pull side 4 8 1-3 1 1 3 Door-leaf fixing, push side 3 8 1-3 1 1 3 Frame fixing, pull side 4 8 1-3 1 1 3 Frame fixing, push side 3 8 1-3 1 1 3
Manufacturing Plant:	DO 2.32
Remarks:	Optionally with or without mounting plate, optionally slide channel assembly GS-B, GS-H, GS-HF, GS-STM or RIII, optionally sliding arm 6*336 mm, 4*336 mm oder 4*358mm.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Intended Use:

On single- and double leaf fire- and smoke protection doors

<i>Essential properties</i>	<i>Clauses with requirements in EN 1154:1996/A1:2002/AC:2006</i>	<i>Performance of the product</i>
<i>Self-closing</i>	5.2.1 general 5.2.3 closing torque 5.2.4 opening torque 5.2.5 efficiency 5.2.6 closing time 5.2.7 opening angle Door-leaf fixing, pull side Door-leaf fixing, push side Frame fixing, pull side Frame fixing, push side 5.2.8 overload test 5.2.9 temperature dependence 5.2.10 leakage 5.2.11 damage 5.2.12 latch regulation 5.2.13 back check 5.2.14 delayed action 5.2.15 adjustable force 5.2.16 play at zero point position 5.2.18 use on fire-/ smoke doors	passed passed (size 1-3) passed (size 1-3) passed (size 1-3) passed (size 1-3) passed (class 4) passed (class 3) passed (class 4) passed (class 3) passed (size 1-3) passed (size 1-3) passed (size 1-3) passed (size 1-3) passed (size 1-3) not applicable passed (size 1-3) not applicable passed (class 1)
<i>Durability Self-closing</i>	With slide channel arm assembly GS-B, GS-H, GS-HF, GS-STM 5.2.2 Durability 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance With slide channel arm assembly RIII 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance	passed (class 8) passed class 4 (240h) passed class 4 (240h) passed class 4 (240h) passed class 0: no requirements passed class 0: no requirements passed class 0: no requirements
<i>Dangerous substances</i>	Annex ZA.3	The manufacturer has not declared any dangerous substances.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

List of Products

Type:	„ECO TS-33“
Description:	Hydraulic door closer with controlled closing sequence with or without back check
Arm system:	slide channel arm assembly (shot and long)
Installation:	Door-leaf fixing, pull side in accordance with manufacturer specification (standard installation) Door-leaf fixing, push side in accordance with manufacturer specification Frame fixing, pull side in accordance with manufacturer specification Frame fixing, push side in accordance with manufacturer specification
Size:	3
Classification:	Door-leaf fixing, pull side 4 8 3 1 1 3 Door-leaf fixing, push side 3 8 3 1 1 3 Frame fixing, pull side 4 8 3 1 1 3 Frame fixing, push side 3 8 3 1 1 3
Manufacturing Plant:	DO 2.32
Remarks:	Optionally with or without mounting plate, optionally slide channel assembly GS-B, GS-H, GS-HF, GS-STM or RIII, optionally sliding arm 6*336 mm, 4*336 mm oder 4*358mm.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Intended Use:

On single- and double leaf fire- and smoke protection doors

<i>Essential properties</i>	<i>Clauses with requirements in EN 1154:1996/A1:2002/AC:2006</i>	<i>Performance of the product</i>
<i>Self-closing</i>	5.2.1 general 5.2.3 closing torque 5.2.4 opening torque 5.2.5 efficiency 5.2.6 closing time 5.2.7 opening angle Door-leaf fixing, pull side Door-leaf fixing, push side Frame fixing, pull side Frame fixing, push side 5.2.8 overload test 5.2.9 temperature dependence 5.2.10 leakage 5.2.11 damage 5.2.12 latch regulation 5.2.13 back check 5.2.14 delayed action 5.2.15 adjustable force 5.2.16 play at zero point position 5.2.18 use on fire-/ smoke doors	passed passed (size 3) passed (size 3) passed (size 3) passed (size 3) passed (class 4) passed (class 3) passed (class 4) passed (class 3) passed (size 3) passed (size 3) passed (size 3) passed (size 3) passed (size 3) passed (size 3) not applicable passed (size 3) not applicable passed (class 1)
Durability Self-closing	With slide channel arm assembly GS-B, GS-H, GS-HF, GS-STM 5.2.2 Durability 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance With slide channel arm assembly RIII 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance	passed (class 8) passed class 4 (240h) passed class 4 (240h) passed class 4 (240h) passed class 0: no requirements passed class 0: no requirements passed class 0: no requirements
<i>Dangerous substances</i>	<i>Annex ZA.3</i>	<i>The manufacturer has not declared any dangerous substances.</i>

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

List of Products

Type:	„ECO TS-41“
Description:	Hydraulic door closer with controlled closing sequence with or without back check
Arm system:	slide channel arm assembly (shot and long)
Installation:	Door-leaf fixing, pull side in accordance with manufacturer specification (standard installation) Door-leaf fixing, push side in accordance with manufacturer specification Frame fixing, pull side in accordance with manufacturer specification Frame fixing, push side in accordance with manufacturer specification
Size:	1-4
Classification:	Door-leaf fixing, pull side 4 8 1-4 1 1 3 Door-leaf fixing, push side 3 8 1-4 1 1 3 Frame fixing, pull side 4 8 1-4 1 1 3 Frame fixing, push side 3 8 1-4 1 1 3
Manufacturing Plant:	DO 2.32
Remarks:	Optionally with or without mounting plate, optionally slide channel assembly GS-B, GS-H, GS-HF, GS-STM or RIII, optionally sliding arm 6*336 mm, 4*336 mm oder 4*358mm.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Intended Use:

On single- and double leaf fire- and smoke protection doors

<i>Essential properties</i>	<i>Clauses with requirements in EN 1154:1996/A1:2002/AC:2006</i>	<i>Performance of the product</i>
<i>Self-closing</i>	5.2.1 general 5.2.3 closing torque 5.2.4 opening torque 5.2.5 efficiency 5.2.6 closing time 5.2.7 opening angle Door-leaf fixing, pull side Door-leaf fixing, push side Frame fixing, pull side Frame fixing, push side 5.2.8 overload test 5.2.9 temperature dependence 5.2.10 leakage 5.2.11 damage 5.2.12 latch regulation 5.2.13 back check 5.2.14 delayed action 5.2.15 adjustable force 5.2.16 play at zero point position 5.2.18 use on fire-/ smoke doors	passed passed (size 1-4) passed (size 1-4) passed (size 1-4) passed passed (class 4) passed (class 3) passed (class 4) passed (class 3) passed (size 1-4) passed (size 1-4) passed (size 1-4) passed (size 1-4) passed (size 1-4) passed (size 1-4) not applicable passed (size 1-4) not applicable passed (class 1)
<i>Durability Self-closing</i>	With slide channel arm assembly GS-B, GS-H, GS-HF, GS-STM 5.2.2 Durability 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance With slide channel arm assembly RIII 5.2.17.1 Corrosion resistance 5.2.17.2 Corrosion resistance 5.2.17.3 Corrosion resistance	 passed (class 8) passed class 4 (240h) passed class 4 (240h) passed class 4 (240h) passed class 0: no requirements passed class 0: no requirements passed class 0: no requirements
<i>Dangerous substances</i>	Annex ZA.3	The manufacturer has not declared any dangerous substances.